



Clarification/Response on Bidder's query

SN	Bid Document	Text in Bidding Document	Employer's Response/Clarification																		
1	Section 3 2.2.6 (c) Functional Guarantee of the Facilities	<p>The minimum and maximum requirements stated in the specification for functional guarantee required for energy consumption are:</p> <table border="1"> <thead> <tr> <th>S No</th> <th>Parameters</th> <th>Minimum Functional Guarantee values</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Hanumanghat</td> <td>482 kWh per Million liter</td> </tr> <tr> <td>2</td> <td>Gokarna</td> <td>482 kWh per Million liter</td> </tr> </tbody> </table>	S No	Parameters	Minimum Functional Guarantee values	1	Hanumanghat	482 kWh per Million liter	2	Gokarna	482 kWh per Million liter	<p>The maximum requirements stated in the specification for functional guarantee required for energy consumption are:</p> <table border="1"> <thead> <tr> <th>S No</th> <th>Parameters</th> <th>Maximum Functional Guarantee values</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Hanumanghat</td> <td>1600 kWh per Million liter</td> </tr> <tr> <td>2</td> <td>Gokarna</td> <td>1200 kWh per Million liter</td> </tr> </tbody> </table>	S No	Parameters	Maximum Functional Guarantee values	1	Hanumanghat	1600 kWh per Million liter	2	Gokarna	1200 kWh per Million liter
S No	Parameters	Minimum Functional Guarantee values																			
1	Hanumanghat	482 kWh per Million liter																			
2	Gokarna	482 kWh per Million liter																			
S No	Parameters	Maximum Functional Guarantee values																			
1	Hanumanghat	1600 kWh per Million liter																			
2	Gokarna	1200 kWh per Million liter																			