



Response on Bidder's queries/Request

SN	Bid Document	Bidder's Queries/Request	Employer's Response/Clarification
1.	VOLUME II A: EMPLOYER'S REQUIREMENT SECTION 6: EMPLOYER'S REQUIREMENT Sub-Clause 11.6	Distribution Transformer Please clarify whether the Contractor has to supply one single transformer or one working and one standby transformer.	The contractor basically should provide one distribution transformer for utility power and one diesel generator for back-up power. However, the bidder can propose an additional standby transformer for reliability of power supply.
2.	VOLUME II A: EMPLOYER'S REQUIREMENT SECTION 6: EMPLOYER'S REQUIREMENT Sub-Clause 10.2	Please clarify the in detail the requirement on i) Alarm Printer (Including desk) ii) Logging & Report Printer (Including desk) iii) Printer server of the Sub-Clause 10.2 of Employer Requirement.	There are no detailed specifications, but at the time of construction, the contractor should provide the office equipment with latest specification.
3.	VOLUME II A: EMPLOYER'S REQUIREMENT SECTION 6: EMPLOYER'S REQUIREMENT	Whether the Employer requires the cell phone or other devices to Accomplish the work of wireless network.	Contractor shall provide the telephone and internet service system for Employer/Operator in the treatment plants.
4.	VOLUME I: BIDDING DOCUMENT SECTION 4 - BIDDING FORMS Technical Proposal	Please confirm as to when do the Employer require the Manufacturer Certificate. Can this be submitted later on post qualification or prior to execution of the project.	Equipment qualities and prices may vary depending on the Manufacturer, so it must be submitted at the time of bidding.
5.	VOLUME II A: EMPLOYER'S REQUIREMENT SECTION 6: EMPLOYER'S REQUIREMENT Sub-Clause 11.6	"Primary and Secondary Treatment Facility" Circular type of PST does not have the provision of FRP Cover. Please clarify this matter.	As indicated in bidding documents, the bidder shall propose the FRP covers on the Primary Sedimentation tanks regardless of shape of tanks. Please follow the bidding documents.
6	VOLUME I ITB 24.1, 24.2	Extension of the deadline for the submission of bid	Deadline for the submission of bid remain unchanged.



Clarification/Response on Bidder's query

SN	Bid Document	Text in Bidding Document	Employer's Response/Clarification																		
1	Section 3 2.2.6 (c) Functional Guarantee of the Facilities	<p>The minimum and maximum requirements stated in the specification for functional guarantee required for energy consumption are:</p> <table border="1"> <thead> <tr> <th>S No</th> <th>Parameters</th> <th>Minimum Functional Guarantee values</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Hanumanghat</td> <td>482 kWh per Million liter</td> </tr> <tr> <td>2</td> <td>Gokarna</td> <td>482 kWh per Million liter</td> </tr> </tbody> </table>	S No	Parameters	Minimum Functional Guarantee values	1	Hanumanghat	482 kWh per Million liter	2	Gokarna	482 kWh per Million liter	<p>The maximum requirements stated in the specification for functional guarantee required for energy consumption are:</p> <table border="1"> <thead> <tr> <th>S No</th> <th>Parameters</th> <th>Maximum Functional Guarantee values</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Hanumanghat</td> <td>482 kWh per Million liter</td> </tr> <tr> <td>2</td> <td>Gokarna</td> <td>482 kWh per Million liter</td> </tr> </tbody> </table>	S No	Parameters	Maximum Functional Guarantee values	1	Hanumanghat	482 kWh per Million liter	2	Gokarna	482 kWh per Million liter
S No	Parameters	Minimum Functional Guarantee values																			
1	Hanumanghat	482 kWh per Million liter																			
2	Gokarna	482 kWh per Million liter																			
S No	Parameters	Maximum Functional Guarantee values																			
1	Hanumanghat	482 kWh per Million liter																			
2	Gokarna	482 kWh per Million liter																			